

November 14, 2016

Mr. Erik Waite
Pacific Seismic Products, Inc.
233 East Avenue H8
Lancaster, CA 93535


Subject: Earthquake-Actuated Automatic Gas Shutoff Valves Devices
Product name: Pacific Seismic Actuated Automatic Three-way Valve
Product numbers: Model 400
DSA label assigned: **DSA 16-E02**
Lab test done by: Underwriters Laboratories, Inc.
Lab test number: SA5723-20151030, Dated 11/04/15
Current standard: ANSI/ASCE/SEI 25-06

Dear Mr. Waite:

The Division of the State Architect (DSA) received your DSA-191 application on November 7, 2016 for certification of an earthquake actuated automatic three-way valve (EV) for use with a pneumatic or spring operated actuator to shutoff a gas valve. Starting January 1, 2017, Pacific Seismic Products will need to have this newly issued label assignment marked on each EV. The UL reports have been verified by DSA for the seismic and ruggedness of the EV per ANSI/ASCE/SEI 25-06 and the certification is contingent upon the following:

1. The CA-DSA label shall appear on the EV markings and the container in compliance with Section 1378, Subchapter 5, Title 21, California Code of Regulations (CCR) labeling requirements.
2. Verified inspection services shall notify DSA in writing within 30 days of any changes in company ownership, company address, inspection forms, procedures or any other changes as noted in Section 1382 (g) Title 21, CCR.
3. Independent third party quality control inspections shall be conducted as required by Section 1382(a), Title 21, CCR. Frequency of inspection shall be per ANSI/ASCE/SEI 25-2006, Section 3. Copies of the verified inspection reports are to be sent to DSA within 30 days of date of inspection as required by Section 1382 (f) Title 21, CCR.
4. Any changes in or to the certified valve or manufacturing procedures (standards/code) require a new certification per Section 1374, Certification Limitation, Title 21, CCR.

Sincerely,



Lydia Barrón, LEED® AP
Architectural Associate / DSA High Performance Section (HPS)
Lydia.Barron@dgs.ca.gov
Phone: 916-327-0535